

### CARBON IMPREGNATED CELLULOSE

- Economically priced
- Dual purpose cartridge provides bad taste, odor, and chlorine taste & odor reduction, as well as sediment filtration\*
- Design maximizes dirt holding capacity
- For municipal/chlorinated water (not recommended for well water applications)
- Recommended for point of use filtration



COMPONENT

The W5CIP is Tested and Certified by NSF International.



### GRANULAR ACTIVATED CARBON (GAC)

- Effective taste, odor, and chlorine taste & odor reduction
- Cartridge design ensures that water passes through the entire length of the carbon bed, maximizing contact time
- Nominal 20-micron post filter reduces carbon fines and suspended particles



### CARBON BLOCK CARTRIDGES

- Excellent for bad taste, odor, and chlorine taste & odor reduction\*
- Specialty blocks are capable of reducing cysts, lead and certain volatile organic compounds (VOCs)\*



COMPONENT

The W.5CB and WLC-R are Tested and Certified by NSF International.



Certain carbon cartridges reduce chlorine taste & odor, other tastes and odors, VOCs, lead and cysts. Choose the cartridge that best fits your water conditions.

\*\* As tested by American Plumber

Certain states require system registration or certification for health-related reduction claims

c a r t r i d g e s

Drinking Water	Micron Rating†	3/8" SlimLine® Housings	W385-PR (5")	W38-PRA (10")	W38-PRB (10")	W38-PRQC (10")	3/4" Standard Housings	W34-PR (10")	WC34-PRB (10")	WC34-PR (10")	WVC34 (10")	W34-PRB (10")	3/4" High Temp Housing	WH34 (10")	3/4" Stainless Steel	ST-1 (10")	ST-2 (20")	ST-3 (30")
Filter Cartridge		Flow Rate* in gallons per minute																
W.5CB478	0.5	1																
W5CIP478	5	1																
WGC478	—	1																
W.5CB	0.5		1	1	1													
WLC-R	0.5		0.6	0.6	0.6													
W5CIP	5		5	5	5		5	5	5	5	5			5		5	10	15
WCC	—		1	1	1													

† Micron ratings are nominal  
 \* Flow rates are calculated for cartridges according to the housing in which they are being used.

### Carbon Impregnated Cellulose

Model #	Part #	Medium	Micron Rating** (nominal)	Chlorine Taste & Odor Reduction @ Flow Rate**	Maximum Flow Rate (GPM)	Diameter	Length
W5CIP478	155022-52	Carbon Impregnated Cellulose	5	>2,500 Gal. @ 0.5 GPM	2	2½"	4¾"
W5CIP	155002-52	Carbon Impregnated Cellulose	5	>5,000 Gal. @ 1 GPM	5	2½"	9¾"

### Granular Activated Carbon (GAC)

Model #	Part #	Medium	Chlorine Taste & Odor Reduction @ WFlow Rate**	Maximum Flow Rate (GPM)	Diameter	Length
WGC478	155110-51	Granular Activated Carbon	>750 Gal. @ 0.5 GPM	1	2½"	4¾"
WCC	155155-51	Granular Activated Coconut Carbon	>500 Gal. @ 1 GPM	1	2½"	9¾"

### Carbon Block

Model #	Part #	Medium	Reduces**	Micron Rating** (nominal)	Chlorine Taste & Odor Reduction @ Flow Rate**	Lead (gallons)	VOCs (gallons)	Max. Flow Rate	Diameter	Length
W.5CB478	155169-51	Acid-washed Bituminous	Chlorine Taste & Odor, Cyst	0.5	>3,000 Gal. @ 1 GPM	N/A	N/A	1	2½"	4¾"
W.5CB	155162-51	Acid-washed Bituminous	Chlorine Taste & Odor, Cyst	0.5	>20,000 Gal. @ 1 GPM	N/A	N/A	1	2½"	9¾"
WLC-R	155268-51	Acid-washed Bituminous	Chlorine Taste & Odor, Cyst, Lead & VOC	0.5	>20,000 Gal. @ 0.6 GPM	600**	300**	0.6	2½"	9¾"

\*\* As tested by American Plumber  
 Certain states require system registration or certification for health-related reduction claims



502 Indiana Avenue, P.O. Box 1047, Sheboygan, WI 53082-1047 U.S.A.

Phone 800.645.5428 • Fax 888.588.9388 • www.americanplumber.com